

WKS (used 1985-May 2010)

-VS-

WKSL (started June 2010 - Current)

(the differences between)

- ✓ **WKS** was a R12 coolant
WKSL uses 134a coolant

- ✓ **WKS** had a max line of 100'
WKSL max line set is 50'

- ✓ **WKS** were a pump down system with an expansion valve and solenoid valve.

- ✓ **WKSL** must have a low voltage wire between the air handler and the condenser

- ✓ **WKS** had a manual thermostat
WKSL model have the Sentry III controller

Physical Size of the models:

- ✓ **WKS 4000** and the **WKSL 4000** have the same housing sizes the difference is on the inside of the unit.

- ✓ **WKS 2200** and the **WKSL 2200** the housings are completely different sizes. Please see a copy of the instructions for the current size chart.